

PHOTOLUMINESCENT 'FINAL EXIT' SIGN

Code: PFE



A simple, Glow in the Dark 'Final Exit' Safety Egress Sign.

FEATURES

- Meets New York City Building Code Reference Standard RS 6-1 & 6-1A and Local Law 26
- Easy to mount
- Emergency Egress/Safety Sign
- Explosion proof semi-rigid plastic
- No power or wiring required
- Requires continued exposure to at least 54 LUX illumination
- Indoor use only

WARRANTY INFORMATION

Any component that fails due to manufacturer's defect is guaranteed for 1 year. The warranty only covers products installed and maintained in accordance with the instructions provided by their respective manufacturer and no warranty is made with respect to any of our products that are otherwise installed or maintained. For full warranty details, visit our Warranty Section.

Conformance to Codes and Standards

Meets New York City Building Code Reference Standard RS 6-1 & 6-1A and Local Law 26

ORDERING INFORMATION

Series	Sides	Exit Direction
PFE-L	Single	Exit Forward Left Side
PFE-R		Exit Forward Right Side
PFE-UL		Exit Up Left
PFE-UR		Exit Up Right

CONSTRUCTION

This photoluminescent Egress Sign is constructed with non-toxic, non-radioactive Glo Brite® photoluminescence technology.

ILLUMINATION

Under normal lighting conditions, these signs are highly visible. In the event of low or no lighting due to power failure, the lettering on the signs will "Glow in the Dark". (Signs must be "charged" to glow -- requires 54 LUX (5ft candles) of fluorescent, metal halide or mercury vapor light illumination for 60 minutes).

EMERGENCY OPERATION

Upon failure of the normal utility power, this unit will provide at least 90 minutes of illumination. *This sign must be charged for a minimum of 60 minutes prior to being fully operational.

INSTALLATION

No electricity or battery required. These signs can be easily placed on any surface using double-sided tape (not included).

DIMENSIONS



Weight : 2.00 lb

3170 Scott St, Vista, CA 92081
Phone: 877-352-3948 | Fax: 877-352-3949
info@exitlightco.com