

## NOT AN EXIT PHOTOLUMINESCENT EGRESS SIGN

Code: PNE-D



A simple, Glow in the Dark Not An Exit Egress Sign.



### CONSTRUCTION

This photoluminescent Egress Sign is constructed with non-toxic, non-radioactive Glo Brite® photoluminescence technology.

### ILLUMINATION

Under normal lighting conditions, these signs are highly visible. In the event of low or no lighting due to power failure, the lettering on the signs will "Glow in the Dark". (Signs must be "charged" to glow -- requires 54 LUX (5ft candles) of LED, fluorescent, metal halide or mercury vapor light illumination for 60 minutes).

### ELECTRICAL COMPONENTS

The PNE-D sign does not require any type of electrical components.

### EMERGENCY OPERATION

Upon failure of the normal utility power, this unit will provide at least 90 minutes of illumination. \*This sign must be charged for a minimum of 60 minutes prior to being fully operational.

### FEATURES

- Meets New York City Building Code Reference Standard RS 6-1 & 6-1A and Local Law 26
- Meets UL 1994
- Emergency Egress/Safety Sign
- Explosion proof semi-rigid plastic
- No power or wiring required
- Requires continued exposure to at least 54 LUX illumination
- Indoor use only

### WARRANTY INFORMATION

Any component that fails due to manufacturer's defect is guaranteed for 1 year. The warranty only covers products installed and maintained in accordance with the instructions provided by their respective manufacturer and no warranty is made with respect to any of our products that are otherwise installed or maintained. For full warranty details, visit our Warranty Section.

### Conformance to Codes and Standards

Meets New York City Building Code Reference Standard RS 6-1 & 6-1A and Local Law 26

### INSTALLATION

No electricity or battery required. These signs can be easily installed using one of the four following methods (Instructions Provided):

- 1) Peel and Stick
- 2) Foam Tape
- 3) Mechanically Fasten
- 4) Construction Adhesive

