

## Instructions for PA1 Series Photoluminescent Exit Sign

**IN THE BOX:** Photoluminescent Exit Sign, (2) Two Chevrons, Installation Instructions, and Black frame.

### **CAUTION: EXTERNAL ILLUMINATION SOURCE REQUIRED**

Sign must be installed in a location where a minimum of 5-foot candles (54 lux) of fluorescent or LED lighting is available during all times of building occupancy.

### INSTALLATION

- Sign must be charged for a minimum of 60 minutes to become operational.
- External illumination (fluorescent or LED lighting) must be dependable and supplied by a circuit not controlled by automatic timers or sensors.
- External illumination source must be powered during all times of building occupancy.
- Light level upon the face of the sign must be reassessed if any changes in external lighting take place.
- Cleaning of the sign must be done with non-abrasive cloth dampened in water.
- Periodic visibility inspections are to be performed regularly and in accordance with applicable installation codes – Refer to NFPA 101 for more information.
- Sign is to be installed indoors ONLY, where it will not be exposed to direct sunlight or water exposure.

### CHEVRONS

Sign includes (2) two detachable chevrons, may be applied to clearly demonstrate path of egress.



## VIEWING DISTANCE

PA1-50: UL 924 Listed for 50-foot maximum legible viewing distance.

PA1-100: UL 924 Listed for 100-foot maximum legible viewing distance.

## MOUNTING

**No Frame:** (4) Four mounting holes are drilled for unframed signs. For best practice – mark the mounting holes on the wall using the exit sign as a guide. Drill the holes and screw the exit sign to the wall through the drilled mounting holes.

**With Frame:** Frame is ready for mounting. (2) two holes are located in the back that can be used for wall mount applications. For best practice – mark the mounting holes on the wall using the frame as a guide. After frame has been mounted, slide the exit sign inside the black frame.

## CODES AND REGULATIONS

- UL924 Listed (Both for 50', 75', and 100' viewing distances)
- Meets current NFPA Life Safety Code 101 and OSHA requirements
- Operation temperature: 0°F to 104°F

**-SAVE THESE INSTRUCTIONS FOR FIRE SAFETY INSPECTIONS-**



3170 Scott Street

Vista, CA 92081

(P) 877-352-3948

(E) [info@exitlightco.com](mailto:info@exitlightco.com)

(W) [www.exitlightco.com](http://www.exitlightco.com)